

# OFFICE OF THE ILLINOIS STATE FIRE MARSHAL Division of Technical Services

1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)524-7605

### FOR OFFICE USE ONLY

Facility # 2-007081
Permit # 00417-2010FLX
Request Rec'd 04/16/2010
Amended Date
Approval Date 4/16/2010 JC
Permit Expires 10/16/2010

## Permit for UPGRADE or REPAIR of FLEX CONNECTOR for existing Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair flex connector(s) is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for flex connector of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:
Speedway SuperAmerica, LLC P.O. Box 1500 Springfield, OH 45501-1500	Speedway Unit #5362 800 West Maple New Lenox, Will Co., IL
Contact: Michelle McKee (937) 863-7834	Contact: 'Khalid Mehmood (815) 485-3407

### (3) <u>UPGRADE OR REPAIR OF FLEX CONNECTORS:</u>

- (a) Number and size of tanks being upgraded or repaired: (TK # 1, 2, 3, 4) 10,000 gallons, (TK # 5, 6) 4,000 gallons
- (b) Type of flex connector(s):
- (c) Product stored in each tank: (TK # 1, 2, 3, 4) Gasoline, (TK # 5) Diesel Fuel, (TK # 6) Kerosene
- (d) Corrosion Protection being installed with flex connector(s): (TK # 1, 2, 3, 4, 5, 6) (Installing) Sacrificial Anode Cathodic Protection with Dielectric Coating to flex connectors and any exposed steel piping at all submersible sumps, and if necessary, at all dispenser sumps.
- (4) The owner must notify this Office when completion of flex connector upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for flex connector to the OSFM prior to the work being performed. Both forms can be obtained at <a href="https://www.state.il.us/osfm">www.state.il.us/osfm</a> or by calling (217)785-1020.

#### (5) **SPECIAL CONTINGENCIES**:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
Advanced Corrosion Control Technologies., Inc. 2519 47th Court	Contact Person: Phone:
Kenosha, WI 53144	Contractor Registration # Exp.

Janu J Coffey

Sincerely,

cc: Storage Tank Safety Specialist -Fire Department -Office Coordinator -

Division File

(Rev. - 1/98)