



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-012899
Permit # 00386-2010UPG
Request Rec'd 04/12/2010
Amended Date
Approval Date 4/13/2010 JC
Permit Expires 10/13/2010

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: UPS Freight 1000 Semmes Avenue, Richmond, VA 23224 Contact: Larry Cross (708) 210-3838	(2) FACILITY - name and address where tanks are located: Overnite Transportation (Chicago) 6633 West 75th Street Bedford Park, Cook Co., IL Contact: Danny (708) 210-3838
--	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired:* (TK # 6, 7) - 20,000 gallons

(b) *Type of tanks:*

(c) *Type of piping:*

(d) *Product to be stored in each tank:* (TK # 6, 7) - Diesel Fuel

(e) *Type of leak detection being used:*

Tank:

Piping: (TK # 6, 7) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 at new transition sump only
(see contingencies).

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES:** Currently there is approximately 18" of fiberglass piping exposed above ground where the piping leaves underground and comes above ground on inside wall of canopy building hang over. Contractor will saw cut concrete around where the fiberglass piping comes above ground, and excavate to piping elbow below ground, cut back fiberglass piping underground, install new below ground transition sump, hook to existing fiberglass piping and run into transition sump. Steel piping will run with sheer valve from inside transition sump to above grade and re-hook to existing steel piping.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Contact Person:

Phone:

Contractor Registration # Exp.

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 1/98)