



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)524-7605

<u>FOR OFFICE USE ONLY</u>
Facility # 2-029288
Permit # 00304-2010ABN
Request Rec'd 03/22/2010
Amended Date
Approval Date 3/23/2010 JC
Permit Expires 9/23/2010

Permit for ABANDONMENT IN PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to abandon in place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Saraf, Inc. 3600 Berdnick Street Rolling Meadows, IL 60008</p> <p>Contact: Farooq Sultan (630) 674-9403</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Minuteman Citgo #335 415 New Avenue Romeoville, Will Co., IL</p> <p>Contact: Phil Dittamore (708) 447-1999</p>
---	--

(3) ABANDONMENT IN PLACE OF TANKS:

- (a) Number and size tanks being abandoned:* (TK # 4) - 6,000 gallons
- (b) Location of tanks being abandoned:* **The tank is located adjacent to tank #3. Removing tank #4 would undermine the earthen support for the active tank #3 which then could also jeopardize the support of tanks 1 & 2.**

- (4)** This permit is VOID if contamination is revealed during abandonment procedures or if tanks are not as indicated on your granted permit site plan. If contamination is revealed, this abandonment can continue only when the contaminated site section (2) of the certification on site condition has been submitted to our Office.
- (5) SPECIAL CONTINGENCIES:** **Tank piping for this tank will also be abandoned properly since it is running in the same piping trench as the piping for the other three tanks going to the canopy / dispensers.**
- (6)** **The owner must notify this Office when completion of tank abandonment has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.state.il.us/osfm or by calling (217)785-1020.**

<p>(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u></p>	
<p>ABD Tank & Pump Company, Inc. 730 Industrial Drive Elmhurst, IL 60126</p>	<p>Contact Person: Jim Veverka Phone: (630) 530-9880</p> <p>Contractor Registration # IL-1733 Exp.</p>

Sincerely,

cc: Storage Tank Safety Specialist -
 Fire Department -
 Office Coordinator -
 Division File
 (Rev. - 1/98)