

## OFFICE OF THE ILLINOIS STATE FIRE MARSHAL Division of Technical Services

1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)524-7605

## FOR OFFICE USE ONLY

Facility # 2-031976
Permit # 00303-2010UPG
Request Rec'd 03/22/2010
Amended Date
Approval Date 3/23/2010 JC
Permit Expires 9/23/2010

## Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE**.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:
PACE Suburban Bus 550 West Algonquin Road Arlington Heights, IL 60005	Pace North Shore Facility 2330 Oakton Street Evanston, Cook Co., IL
Contact: Dave Szaflarski (847) 228-4228	Contact: Tony

## (3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 1, 2) 20,000 gallons
- (b) Type of tanks:
- (c) Type of piping: (TK # 1, 2) (Installing "possibly") partial Fiberglass Double Wall for the potential possibility of replacing damaged sump penetration boots to prevent possible water ingress. If this is the case, the contractor will cut back the existing product piping to outside the sump wall, install new penetration boot, and run piping back into sump. If all boots are in good shape there will be no piping work to be done outside of the containment sumps., (TK # 1, 2) (Installing) Flex Connector Steel in the submersible sumps to include short sections of steel pipe inside of sumps to accommodate the installation.
- (d) Product to be stored in each tank: (TK # 1, 2) Diesel Fuel
- (e) Type of leak detection being used:

Tank:

Piping:

(f) Corrosion Protection being used:

Tank:

Piping:

- (g) Spill containment devices:
- (h) Overfill prevention devices:
- (i) Manway accessible at grade:
- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at <a href="https://www.state.il.us/osfm">www.state.il.us/osfm</a> or by calling (217)785-1020.
- (5) <u>SPECIAL CONTINGENCIES</u>:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:		
	Contact Person: Phone:	
	Contractor Registration # Exp.	

James of Coffey

Sincerely,

Jim Coffey

(Rev. - 1/98)