



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-029322
Permit # 00198-2010UPG
Request Rec'd 02/25/2010
Amended Date
Approval Date 2/26/2010 JC
Permit Expires 8/26/2010

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Commonwealth Edison/Exelon Corporation 3 Lincoln Center, Environmental Services Department Oakbrook Terrace, IL 60181-4260 Contact: Dan Stankowske (815) 673-5220	(2) FACILITY - name and address where tanks are located: Commonwealth Edison 30000 Governors Highway University Park, Will Co., IL Contact: Randy McCord (630) 576-6312
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 1, 2) - 10,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 1, 2) - (Installing) Sheer Valves, (TK # 1, 2) - (Installing) Flexible Double Wall OPW Flexworks CP-15 non corrosive from tank to dispensers.
- (d) *Product to be stored in each tank:* (TK # 1) - Diesel Fuel, (TK # 2) - Gasoline
- (e) *Type of leak detection being used:*
Tank:
Piping: (TK # 1, 2) - (Installing) Stand Alone Dispenser Pan Sensor Other Veeder Root non discriminating at three dispensers. (Tank sumps already have existing sump sensors. Line leak detectors are also existing according to our records). New tank sumps and new dispenser sumps will also be installed.
- (f) *Corrosion Protection being used:*
Tank:
Piping:
- (g) *Spill containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Contact Person: Steve Tuttle Phone: Contractor Registration # Exp.

Sincerely,

