



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
 Division of Petroleum and Chemical Safety  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)785-1020

**FOR OFFICE USE ONLY**  
 Facility # 2-016441  
 Permit # 01170-2014UPG  
 Request Rec'd 12/09/2014  
 Amended Date  
 Approval Date 12/9/2014 JC  
 Permit Expires 6/9/2015

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:          The Premcor Refining Group, Inc..          One Valero Way          San Antonio, TX 78249          Contact: Craig Goecker (308) 302-837</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:          Former Clark Station #2027          415 Virginia Street          Crystal Lake, McHenry Co., IL          Contact: Kanti Patel (815) 477-4665</p>
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 6) - 12,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 6) - (Installing) submersible pump, (TK # 6) - (Installing) Submersible Sump containment FRP, (TK # 6) - (Installing) partial Steel Single Wall Piping to accommodate the installation of a new submersible pump and sump (**see contingencies section**).
- (d) *Product to be stored in each tank:* (TK # 6) - Gasoline
- (e) *Type of leak detection being used:*  
     *Tank:*  
     *Piping:*
- (f) *Corrosion Protection being used:*  
     *Tank:*  
     *Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES: According to the facility file, the steel piping is being protected by existing impressed current cathodic protection.**

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b></p>	
<p>Metro Environmental Contractors, Inc. dba Metro Tank &amp; Pump Company          1111 West Dundee Road          Wheeling, IL 60090-3906</p>	<p>Contact Person: Larry Cherner          Phone: (847) 465-4000          Contractor Registration # IL-102 Exp. 02/07/2016</p>

Sincerely,

Jim Coffey

