



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)785-1020

FOR OFFICE USE ONLY

Facility # 2-018580  
Permit # 01185-2014UPG  
Request Rec'd 12/11/2014  
Amended Date  
Approval Date 12/11/2014 JC  
Permit Expires 6/11/2015

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Sunny Petroleum, Inc. 647 South York Road Bensenville, IL 60106 Contact: Harshad Patel (630) 594-1353	<b>(2) FACILITY</b> - name and address where tanks are located: Marathon 647 South York Road Bensenville, Du Page Co., IL Contact: Harshad Patel (630) 595-3732
---	---

**(3) UPGRADE OR REPAIR OF TANKS:**

(a) *Number and size of tanks being upgraded or repaired:* (TK # 2) - 8,000 gallons, (TK # 3, 4) - 12,000 gallons

(b) *Type of tanks:*

(c) *Type of piping:* (TK # 2, 3, 4) - (Installing) Dispenser Sumps containment FRP under all four dispensers.

(d) *Product to be stored in each tank:* (TK # 2, 3, 4) - Gasoline

(e) *Type of leak detection being used:*

*Tank:*

*Piping:* (TK # 2, 3, 4) - (Installing) Stand Alone Sensor Interstitial Monitoring Veeder Root non discriminating at all four dispenser sumps only. **(See contingencies section)**

(f) *Corrosion Protection being used:*

*Tank:*

*Piping:*

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES:** **Interstitial piping sump sensors must immediately shut off the submersible pump supplying that line upon detection of release per section 175.640.**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b> BMPC, Inc. 1510 Spring Bay Road, Unit E East Peoria, IL 61611	Contact Person: Brian McCormick Phone: (309) 222-5293 Contractor Registration # IL-002393 Exp. 12/12/2014
--	---

Sincerely,

Jim Coffey

