



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)785-1020

## Amended

**FOR OFFICE USE ONLY**

Facility # 3-040716  
Permit # 01126-2014UPG  
Request Rec'd 11/20/2014  
**Amended Date 12/17/2014**  
Approval Date 11/20/2014 JC  
Permit Expires 5/20/2015

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity: 7-Eleven, Inc. 1722 Routh Street, Fleet 1000, Gas Compliance Dallas, TX 75201 Contact: Scott Thomas Johnson (847) 608-1136	<b>(2) FACILITY</b> - name and address where tanks are located: 7-Eleven Store #34465 1027 18th Avenue East Moline, Rock Island Co., IL Contact: Jessica Seiber (309) 278-0151
--	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 1) - 10,000 gallons, (TK # 3) - 6,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 1, 3) - (Installing) Flexible Double Wall A.P.T. Poly Tech P150SC from existing tanks to existing dispensers.
- (d) *Product to be stored in each tank:* (TK # 1, 3) - Gasoline
- (e) *Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) *Corrosion Protection being used:*
  - Tank:*
  - Piping:* (TK # 1, 3) - (Installing) Flexible Non-Corrosive
- (g) *Spill containment devices, piping, and dispenser containment devices:* (TK # 1, 3) - (Installing) Manhole Pre-manufactured OPW 1C-3112D to replace the existing spill containment.
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES:** Amendment request was received 12/17/14 to include replacement of spill containment for tanks 1 and 3 (original permit was issued by Dan Starks). Sumps at dispensers and submersible are existing as well as sump sensors

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b> Seneca Companies, Inc. 7241 Gaines Street Court Davenport, IA 52806	Contact Person: Jon Radloff Phone: (563) 332-8000 Contractor Registration # IL-598 Exp. 02/23/2016
--	--

Sincerely,

Jim Coffey

