



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)785-1020

## Amended

**FOR OFFICE USE ONLY**

Facility # 2-016462

Permit # 00750-2014UPG

Request Rec'd 08/12/2014

**Amended Date 12/22/2014**

Approval Date 10/8/2014 JC

Permit Expires 4/8/2015

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

|   |   |
|---|---|
| <b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:<br><br>Gas Cap Fuels<br>26025 W. Grand Ave.<br>Ingleside, IL 60041<br><br>Contact: Louay Alani (847) 587-9821 | <b>(2) FACILITY</b> - name and address where tanks are located:<br><br>Gas Cap Fuels<br>26025 W. Grand Ave.<br>Ingleside, Lake Co., IL<br><br>Contact: Louay Alani (847) 587-9821 |
|---|---|

**(3) UPGRADE OR REPAIR OF TANKS:**

**(a) Number and size of tanks being upgraded or repaired:** (TK # 1) - 8,000 gallons, (TK # 2) - 5,000 gallons, (TK # 3) - 4,000 gallons

**(b) Type of tanks:**

**(c) Type of piping:** (TK # 1, 2, 3) - (Installing) Flexible Double Wall NUPI Smartflex to replace all existing product piping, (TK # 1, 2, 3) - (Installing) Submersible Sumps containment FRP, (TK # 1, 2, 3) - (Installing) Dispenser Sumps containment FRP (total of two for the existing dispensers).

**(d) Product to be stored in each tank:** (TK # 1, 2, 3) - Gasoline

**(e) Type of leak detection being used:**

**Tank:**

**Piping:** (TK # 1, 2, 3) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 discriminating containment sump under the two existing dispensers, and at each submersible sump, (TK # 1, 2, 3) - (Installing) Electronic Pressurized Line Leak Detection Veeder Root TLS 350 to replace the existing line leak detectors.

**(f) Corrosion Protection being used:**

**Tank:**

**Piping:** (TK # 1, 2, 3) - (Installing) Flexible Non-Corrosive

**(g) Spill containment devices, piping, and dispenser containment devices:**

**(h) Overfill prevention devices:**

**(i) Manway accessible at grade:**

**(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.**

**(5) SPECIAL CONTINGENCIES: Amendment request was received 12/22/14 to replace all piping for tanks 2 and 3 also. Further, new submersible sumps will be installed for tanks 2 and 3, and also new line leak detectors and interstitial sensors at the submersibles. Interstitial piping sump sensors must immediately shut off the submersible pump supplying that line upon detection of release per section 175.640. Contractor also states he will change out the existing premium float for a diesel float (for the conversion of tank #3 from premium to diesel, and the existing mid-grade tank #2 will be converted to premium). According to the site plan, there is an existing well located 49' 7" from the edge of the existing mid-grade tank (a waiver letter from IEPA has been received). Contractor further states tank #1 is a single wall fiberglass tank, and tank 2 and 3 are single wall steel.**

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Performance Tank, Inc.  
730 Creel Drive  
Wood Dale, IL 60191

Contact Person: Tim Berg  
Phone: (630) 860-9500

Contractor Registration # IL-881 Exp. 10/27/2014

Sincerely,

A handwritten signature in cursive script, reading "Jim Coffey", written over a horizontal line.

Jim Coffey

cc: Storage Tank Safety Specialist -  
Fire Department -  
Division File  
(Rev. - 9/10)