



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

Amended

FOR OFFICE USE ONLY

Facility # 7-029308
Permit # 01157-2014UPG
Request Rec'd 12/01/2014
Amended Date 12/22/2014
Approval Date 12/1/2014 JC
Permit Expires 6/1/2015

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Casey's Retail Company One Convenience Blvd., P.O. Box 3001 Ankeny, IA 50021 Contact: Jill Reams-Widder (515) 965-6238	(2) FACILITY - name and address where tanks are located: Caseys General Store 115 N. Main (SE Corner) Royalton, Franklin Co., IL Contact: Jennifer Price (618) 984-2759
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired:* (TK # 1, 2) - 10,000 gallons
- (b) Type of tanks:*
- (c) Type of piping:* (TK # 1, 2) - (Installing) partial Fiberglass **Double Wall** Ameron to accommodate the new dispenser sumps only, (TK # 1, 2) - (Installing) Dispenser Sumps containment FRP (total of two), (TK # 1, 2) - (Installing) submersible pump to replace the existing submersible pumps (total of two).
- (d) Product to be stored in each tank:* (TK # 1, 2) - Gasoline
- (e) Type of leak detection being used:*
 - Tank:**
 - Piping:** (TK # 1, 2) - (Installing) Electronic Pressurized Line Leak Detection Veeder Root TLS 350
- (f) Corrosion Protection being used:*
 - Tank:**
 - Piping:**
- (g) Spill containment devices, piping, and dispenser containment devices:* (TK # 1, 2) - (Installing) Manhole Pre-manufactured EBW 705
- (h) Overfill prevention devices:* (TK # 1, 2) - (Installing) Overfill Drop Tube Valve OPW 71SO-410C overfill drop tube
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.**

- (5) SPECIAL CONTINGENCIES: Amendment request was received 12/22/14 to indicate the piping repair will be double wall Ameron piping instead of single wall. Upon excavation of the piping, the existing piping at this site was discovered to be double wall instead of single wall. Contractor states he will note this on the registration form to consequently correct the type of existing piping at this facility. See also 175.410(b) for further requirements regarding the replacement of submersible pumps.**

(6) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u> Seneca Companies, Inc. 458 N. Highway 48 Oreana, IL 62554	Contact Person: Chuck Hoenig Phone: (217) 468-2393 Contractor Registration # IL-598 Exp. 02/23/2016
---	--

Sincerely,

A handwritten signature in dark ink, reading "James J. Coffey", is written over a horizontal line.

Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)