



**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)785-1020

**FOR OFFICE USE ONLY**  
Facility # 2-013545  
Permit # 01237-2014UPG  
Request Rec'd 12/29/2014  
Amended Date  
Approval Date 12/29/2014 JC  
Permit Expires 6/29/2015

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  LACOA 19N58 Aztec Lane, Huntley, IL 60142  Contact: Robert Lowry (847) 624-0205	<b>(2) FACILITY</b> - name and address where tanks are located:  Landings Airstrip Corporation 19 N 58 Aztec Lane Huntley, McHenry Co., IL  Contact: Robert Lowry (847) 624-0205
--	--

**(3) UPGRADE OR REPAIR OF TANKS:**

**(a) Number and size of tanks being upgraded or repaired:** (TK # 1) - 12,000 gallons, (TK # 2, 3) - 4,000 gallons

**(b) Type of tanks:**

**(c) Type of piping:**

**(d) Product to be stored in each tank:** (TK # 1, 2) - Aviation Fuel, (TK # 3) - Gasoline

**(e) Type of leak detection being used:**

**Tank:** (TK # 1, 2, 3) - (Installing) Automatic Tank Gauging Veeder Root TLS 350 with CSLD console and probes.

**Piping:**

**(f) Corrosion Protection being used:**

**Tank:**

**Piping:**

**(g) Spill containment devices, piping, and dispenser containment devices:**

**(h) Overfill prevention devices:** (TK # 1, 2, 3) - (Installing) Overfill Alarm Veeder Root TLS 350 , (TK # 3) - (Installing) Overfill Drop Tube Valve Emco Wheaton A1100 Guardian (**see contingencies section also**).

**(i) Manway accessible at grade:**

**(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.**

**(5) SPECIAL CONTINGENCIES: Contractor will also be replacing the drain valve in the existing spill containment bucket for tank #3 only.**

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Walts Petroleum Service Inc.  
5207 E. Jelenik Ave., Autank  
Schofield, WI 54476

Contact Person: Paul Kilde  
Phone: (715) 359-4362  
Contractor Registration # IL-1951 Exp. 04/10/2016

Sincerely,

Jim Coffey

