

FOR OFFICE USE ONLY Facility # 1-039679 Permit # 01240-2014CAT Request Rec'd 12/30/2014 Amended Date Approval Date 12/30/2014 JC Permit Expires 6/30/2015

Permit for INSTALLATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for

Petroleum and Hazardous Substances.

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. A required job schedule for cathodic protection upgrade of underground storage tank(s) and piping must be submitted to the Office of the State Fire Marshal, Division of Petroleum and Chaminal Softw. THE REPAIR APPROVAL DATE

Chemical Safety. THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.		
(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other	(2) <u>FACILITY</u> - name and address where tanks are located:	
business entity:		
VP Oil, Inc.	Lakewood Mini - Mart	
1764 Illinois Street	4742 East 2750 Road	
Roselle, IL 60172	Sandwich, De Kalb Co., IL	
Contact: Paul Unknown	Contact: Ahmad Muhammad (815) 498-4351	

(3) , UPGRADE, OR REPAIR OF CATHODIC PROTECTION SYSTEM:

- (a) Number and size of tanks having cathodic protection installed, upgraded, or repaired: (TK # 1) 12,000 gallons, (TK # 2) 8,000 gallons, (TK # 3) 4,000 gallons
- (b) Type of tanks:
- (c) Type of piping:
- (d) Product to be stored in each tank: (TK # 1, 2) Gasoline, (TK # 3) Diesel Fuel
- (e) Type of leak detection being used:

Tank:

Piping:

(f) Corrosion Protection being used:

Tank:

Piping: (TK # 1, 2, 3) - (Installing) Sacrificial Anode Cathodic Protection (bracelet anodes) for the 4" risers at each submersible sump only.

(g) NACE certified designer:

Certification number:

- (h) Method of integrity assessment of tank(s) being used:
- (4) The owner must notify this Office when completion of cathodic protection upgrade has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for cathodic protection upgrade to the OSFM prior to the work being performed. Both forms can be obtained at <u>www.sfm.illinois.gov</u> or by calling (217)785-1020.
- (5) <u>SPECIAL CONTINGENCIES</u>: Inspector and OSFM note: tank #2 and #3 comprise one single wall compartment tank. There is an existing double wall bulkhead separating the compartments in this tank that is monitored by an interstitial sensor; however, the sensor is only monitoring this bulkhead and of course does not have the ability to monitor the tank as a whole. Reference permit #00726-2000INS.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:		
Pipeco, Inc. 610 29th Street Bettendorf, IA 52722	Contact Person: Art Wentworth Phone: (563) 344-0700	
	Contractor Registration # IL-2034	Exp. 09/28/2016

Jame J Coffey

Jim Coffey

cc: Storage Tank Safety Specialist -Fire Department -Division File (Rev. - 9/10)