



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)785-1020

<u>FOR OFFICE USE ONLY</u>
Facility # 2-034514
Permit # 00029-2015UPG
Request Rec'd 01/14/2015
Amended Date
Approval Date 1/14/2015 JC
Permit Expires 7/14/2015

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Thornton's, Inc. 10101 Linn Station Road, P.O. Box 34230 Louisville, KY 40223</p> <p>Contact: Scott Roberts (800) 928-8022</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Thornton's #121 2401 63rd Street Woodridge, Du Page Co., IL</p> <p>Contact: Lisa Carson (630) 271-0020</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 3) - 12,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 3) - (Installing) Shear Valve under dispenser # 9/10 only.
- (d) *Product to be stored in each tank:* (TK # 3) - Gasoline
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES:** Section 175.410(d) may apply to this permit. The underground storage tank system for tank #2 must be compatible with E-85, as indicated in section 175.415 of Title 41 of the Illinois Administrative Code, and as indicated in the U.S. EPA Federal Register vol. 76, no. 128, July 5th 2011 notices regarding the storage and dispensing of alternative fuels.

<p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</p>	
<p>Beacon SSI, Inc. 2413 South 7th Avenue North Riverside, IL 60546</p>	<p>Contact Person: Patrick Ferriter Phone: (708) 442-7442</p> <p>Contractor Registration # IL-002336 Exp. 01/27/2015</p>

Sincerely,

Jim Coffey

