



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)785-1020

FOR OFFICE USE ONLY

Facility # 5-039012  
Permit # 00036-2015UPG  
Request Rec'd 01/14/2015  
Amended Date  
Approval Date 1/14/2015 JC  
Permit Expires 7/14/2015

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  Ayers Oil Co 4th & Grant, P.O. Box 229 Canton, MO 63435  Contact: Kevin Cain (573) 288-4466	<b>(2) FACILITY</b> - name and address where tanks are located:  Ryder Truck 2800 Commercial Drive Quincy, Adams Co., IL  Contact: Doug Hoffer (217) 228-3126
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 1) - 10,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 1) - (Installing) Flexible Double Wall A.P.T. Poly Tech P150SC to replace all existing product piping (see contingencies section).
- (d) *Product to be stored in each tank:* (TK # 1) - Diesel Fuel
- (e) *Type of leak detection being used:*
  - Tank:*
  - Piping:* (TK # 1) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 300c at the master and satellite dispensers only (according to the contractor, there is an existing sensor at the submersible sump).
- (f) *Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES:** Refer to section 175.300(k)(3) with regards to replacing piping in the same trench as what was existing, and with regards to the permit / contractor requirements. This work as applied for, will only require an upgrade permit to accomplish, since the replaced piping will be within the existing piping trench.

<b><u>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</u></b>  R. L. Hoener Company 2923 Gardner Expressway, P. O. Box 1086 Quincy, IL 62305	Contact Person: Marty Jackson Phone: (217) 223-2190  Contractor Registration # IL-2021 Exp. 05/22/2016
---	---

Sincerely,

Jim Coffey

