



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)785-1020

<u>FOR OFFICE USE ONLY</u>
Facility # 3-001815
Permit # 00037-2015UPG
Request Rec'd 01/14/2015
Amended Date
Approval Date 1/15/2015 DS
Permit Expires 7/15/2015

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity: 7-Eleven, Inc. 1722 Routh Street, Fleet 1000, Gas Compliance Dallas, TX 75201 Contact: Scott Thomas Johnson (847) 608-1136</p>	<p>(2) FACILITY - name and address where tanks are located: 7-Eleven #34455 1636 38th Street Rock Island, Rock Island Co., IL Contact: Vishal Patel (309) 793-0043</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 4) - 6,000 gallons, (TK # 5, 6) - 8,200 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 4, 5, 6) - (Installing) Fiberglass Double Wall Ameron from tanks to dispensers , (TK # 4, 5, 6) - (Installing) Submersible Sumps containment FRP, (TK # 4, 5, 6) - (Installing) Dispenser Sumps containment FRP
- (d) *Product to be stored in each tank:* (TK # 4, 5, 6) - Gasoline
- (e) *Type of leak detection being used:*
Tank:
Piping: (TK # 4, 5, 6) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350R in all new dispenser and submersible sumps
- (f) *Corrosion Protection being used:*
Tank:
Piping: (TK # 4, 5, 6) - (Installing) Fiberglass Non-Corrosive
- (g) *Spill containment devices, piping, and dispenser containment devices:* (TK # 4, 5, 6) - (Installing) Manhole Pre-manufactured OPW 1C-3112
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
Seneca Companies, Inc. 7241 Gaines Street Court Davenport, IA 52806	Contact Person: Jon Radloff Phone: (563) 332-8000 Contractor Registration # IL-598 Exp. 02/23/2016

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist -
 Fire Department -
 Division File
 (Rev. - 9/10)