



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

Permit for Emergency Repair Request on 01/20/2015

FOR OFFICE USE ONLY

Facility # 4-045488
Permit # 00054-2015UPG
Request Rec'd 01/20/2015
Amended Date
Approval Date 1/22/2015 JC
Permit Expires 2/5/2015

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Mac's Convenience Stores, LLC 4080 W. Johnson Moore Pike, Columbus, IN 42701-0347 Contact: Matthew Jordan (812) 379-9227	(2) FACILITY - name and address where tanks are located: Circle K #1445 220 S. Murray Rd. Rantoul, Champaign Co., IL Contact: Store Manager (217) 892-4952
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired:* (TK # 5) - 15,000 gallons
 - (b) Type of tanks:*
 - (c) Type of piping:* (TK # 5) - (Installing) partial Fiberglass Double Wall Ameron Dualoy 3000/LCX to replace a short leaking section of piping at dispenser sump # 9/10 only. Various couplings, test boots, and entry boots will be used for this repair.
 - (d) Product to be stored in each tank:* (TK # 5) - Gasoline
 - (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
 - (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
 - (g) Spill containment devices, piping, and dispenser containment devices:*
 - (h) Overfill prevention devices:*
 - (i) Manway accessible at grade:*
- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.**
- (5) SPECIAL CONTINGENCIES: All emergency repairs require a permit applied for after the fact on the next business day and require a final inspection scheduled pursuant to section 175.320(d)(4) 10 days after issuance of the permit (see section 175.710(a)). The final inspection must be scheduled by 02/05/15.**

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Neumayer Equipment Company, Inc. 5060 Arsenal Street Saint Louis, MO 63139	Contact Person: Alex Griffith Phone: (314) 772-4501 Contractor Registration # IL-1502 Exp. 03/26/2016
---	---

Sincerely,

Jim Coffey

