



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

Amended

FOR OFFICE USE ONLY

Facility # 3-034847

Permit # 01166-2014UPG

Request Rec'd 12/05/2014

Amended Date 01/23/2015

Approval Date 12/5/2014 JC

Permit Expires 6/5/2015

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: VK Food and Mart, Inc. 600 E. Fort St. Farmington, IL 61531 Contact: Ramesh J. Shah (309) 245-4088	(2) FACILITY - name and address where tanks are located: Farmington Gas 600 E. Fort Street Farmington, Fulton Co., IL Contact: Ramish Shah (309) 245-4088
--	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired:* (TK # 2) - 10,000 gallons

(b) *Type of tanks:*

(c) *Type of piping:* (TK # 2) - (Installing) partial Fiberglass Single Wall Piping (**approximately a 3' section as shown on site plan**) to repair a damaged section of the vent line. **See contingencies section.**

(d) *Product to be stored in each tank:* (TK # 2) - Gasoline

(e) *Type of leak detection being used:*

Tank:

Piping:

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES:** Amendment to this permit is to include a site plan to indicate the location of the repair for this vent piping (approximately a 3' section of piping indicated on site plan). This permit may have to be amended once the contractor fully pinpoints the damaged area of this vent line to be repaired (if only a short portion of the existing line is to be repaired, a site plan must be sent to this office to indicate the location of the repaired area). If the entire vent line has to be replaced, a site plan must be sent in to show the new location of the vent line if applicable.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: W J Scott Company 3861 Tozer Road Springfield, IL 62707	Contact Person: Howard Tuttle Phone: (217) 787-6081 Contractor Registration # IL-1949 Exp. 04/18/2016
--	---

Sincerely,

Jim Coffey

