



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

**Permit for Emergency Repair Request on
01/14/2015
Amended**

FOR OFFICE USE ONLY
Facility # 3-042362
Permit # 00049-2015UPG
Request Rec'd 01/16/2015
Amended Date 01/26/2015
Approval Date 1/16/2015 JC
Permit Expires 2/2/2015

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Mac's Convenience Stores, LLC 4080 W. Johnson Moore Pike, Columbus, IN 42701-0347 Contact: Matthew Jordan (812) 379-9227	(2) FACILITY - name and address where tanks are located: Circle K #1427 1514 West Hickory Grove Road Dunlap, Peoria Co., IL Contact: Store Manager (309) 243-9378
--	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired:* (TK # 2) - 10,000 gallons

(b) *Type of tanks:*

(c) *Type of piping:* (TK # 2) - (Installing) Flex Connector Steel to replace the existing leaking flex connector at dispenser sump # 9/10 only, **(TK # 2) - (Installing) Shear Valve to replace the existing shear valve under dispenser # 9/10 only (for the same line as the flex connector replacement).**

(d) *Product to be stored in each tank:* (TK # 2) - Gasoline

(e) *Type of leak detection being used:*

Tank:

Piping:

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES:** Amendment request to include replacement of the shear valve for this same line under dispenser # 9/10 was received 01/23/15. All emergency repairs require a permit applied for after the fact on the next business day and require a final inspection scheduled pursuant to section 175.320(d)(4) 10 days after issuance of the permit (see section 175.710(a)). The final inspection must be scheduled by 02/02/15.

<u>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</u> Neumayer Equipment Company, Inc. 5060 Arsenal Street Saint Louis, MO 63139	Contact Person: Alex Griffith Phone: (314) 772-4501 Contractor Registration # IL-1502 Exp. 03/26/2016
--	---

Sincerely,

A handwritten signature in dark ink, reading "James J. Coffey", is written over a horizontal line.

Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)