



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY

Facility # 2-002167
Permit # 00099-2015UPG
Request Rec'd 02/10/2015
Amended Date
Approval Date 2/10/2015 DS
Permit Expires 8/10/2015

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Melvin Towner 209 Coffin Road Long Grove, IL 60047 Contact: Randall G. Towner (847) 634-3397	(2) FACILITY - name and address where tanks are located: Mel's Standard 209 Coffin Road Long Grove, Lake Co., IL Contact: Randall G. Towner (847) 634-3397
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 1, 2) - 6,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 1, 2) - (Installing) Partial Double Wall A.O. Smith to connect tank #2 product piping to existing partial piping from abandoned tank #3 to supply premium dispensers, (TK # 1, 2) - (Installing) Other elbow fitting
- (d) *Product to be stored in each tank:* (TK # 1, 2) - Gasoline
- (e) *Type of leak detection being used:*
Tank:
Piping:
- (f) *Corrosion Protection being used:*
Tank:
Piping: (TK # 1, 2) - (Installing) Fiberglass Non-Corrosive
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*
- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.
- (5) **SPECIAL CONTINGENCIES:** Converting tank #2 to premium and connecting to existing product piping from abandoned tank #3 (permit 00100-2015ABN) that supply Premium dispensers. Tank #1 product piping to have "T" removed and install a 90 degree fitting to continue to supply RUL dispensers. All work is shown on included site drawing.

<u>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</u> DRW Services, Inc. 600 East Joe Orr Road Chicago Heights, IL 60411	Contact Person: Raymond Kirchner Phone: (708) 758-3222 Ext. 12 Contractor Registration # IL-194 Exp. 03/10/2016
--	---

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)