



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY
Facility # 2-016014
Permit # 00109-2015UPG
Request Rec'd 02/17/2015
Amended Date
Approval Date 2/17/2015 DS
Permit Expires 8/17/2015

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Sisters of St. Francis 1423 Chicago Rd. Chicago Heights, IL 60411 Contact: Mike Pescetto (708) 756-1000 Ext. 56476	(2) FACILITY - name and address where tanks are located: St. James Hosp & Health Center 1423 Chicago Rd. Chicago Heights, Cook Co., IL Contact: Mike Pescetto (708) 756-1000 Ext. 56476
--	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) Number and size of tanks being upgraded or repaired: (TK # 2) - 20,000 gallons

(b) Type of tanks:

(c) Type of piping: (TK # 2) - (Installing) Fiberglass Double Wall Ameron Dualoy 3000/LCX supply/return line from existing tank to new transition sump where piping will enter building, (TK # 2) - (Installing) Submersible Sumps containment FRP, (TK # 2) - (Installing) Transition Sumps FRP fiberglass , (TK # 2) - (Installing) Fiberglass Single Wall Piping Ameron Dualoy 3000L vent piping

(d) Product to be stored in each tank: (TK # 2) - Diesel Fuel

(e) Type of leak detection being used:

Tank:

Piping: (TK # 2) - (Installing) European with No Test Req Suction , (TK # 2) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 in transition sump and tank sump as requested by owner.

(f) Corrosion Protection being used:

Tank:

Piping: (TK # 2) - (Installing) Fiberglass Non-Corrosive

(g) Spill containment devices, piping, and dispenser containment devices:

(h) Overfill prevention devices:

(i) Manway accessible at grade:

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Interstate Pump & Tank, Inc.
901 Niagara Street
Waukesha, WI 53186

Contact Person: Dan McMahon
Phone: (262) 524-8494

Contractor Registration # IL-1171 Exp. 05/07/2016

Sincerely,

Daniel Starks