



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)785-1020

FOR OFFICE USE ONLY

Facility # 4-032430  
Permit # 00112-2015UPG  
Request Rec'd 02/17/2015  
Amended Date  
Approval Date 2/17/2015 DS  
Permit Expires 8/17/2015

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Casey's Retail Company One Convenience Blvd., P.O. Box 3001 Ankeny, IA 50021 Contact: Jill Reams-Widder (515) 965-6238	<b>(2) FACILITY</b> - name and address where tanks are located: Casey's General Store Illinois Route 130 & Martin Street Newton, Jasper Co., IL Contact: Jill Reams-Widder (515) 965-6238
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 1, 2) - 10,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 1, 2) - (Installing) Dispenser Sumps containment FRP under all existing and new dispenser locations, (TK # 1, 2) - (Installing) Flexible Double Wall A.P.T. Poly Tech P175SC from existing tanks to all dispensers, (TK # 1, 2) - (Installing) Submersible Sumps containment FRP
- (d) *Product to be stored in each tank:* (TK # 1, 2) - Gasoline
- (e) *Type of leak detection being used:*  
*Tank:*  
*Piping:* (TK # 1, 2) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 in all dispenser and submersible sumps
- (f) *Corrosion Protection being used:*  
*Tank:*  
*Piping:* (TK # 1, 2) - (Installing) Flexible Non-Corrosive
- (g) *Spill containment devices, piping, and dispenser containment devices:* (TK # 1, 2) - (Installing) Pre-manufactured EBW 705 C1GKT Defender spill containment
- (h) *Overfill prevention devices:* (TK # 1, 2) - (Installing) Overfill Drop Tube Valve OPW 71SO
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES:**

<b><u>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</u></b> Illinois Oil Marketing Equipment, Inc. 850 Brenkman Drive Pekin, IL 61554	Contact Person: Chris Epkins Phone: (309) 347-1819 Contractor Registration # IL-1293 Exp. 02/04/2016
---	--

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist -  
Fire Department -  
Division File  
(Rev. - 9/10)