



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY

Facility # 2-019589
Permit # 00113-2015UPG
Request Rec'd 02/17/2015
Amended Date
Approval Date 2/17/2015 DS
Permit Expires 8/17/2015

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Anula, Inc. 2401 Chambour Drive Buffalo Grove, IL 60089 Contact: Bala Goginem (847) 899-6457	(2) FACILITY - name and address where tanks are located: Clark Gas Station 154 South York Road Bensenville, Du Page Co., IL Contact: Rakesh Patel (630) 766-1807
--	---

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired:* (TK # 1) - 8,000 gallons, (TK # 5, 6) - 4,000 gallons

(b) *Type of tanks:*

(c) *Type of piping:* (TK # 1, 5, 6) - (Installing) Dispenser Sumps containment FRP under dispensers 5/6 and 7/8

(d) *Product to be stored in each tank:* (TK # 1, 5, 6) - Gasoline

(e) *Type of leak detection being used:*

Tank:

Piping: (TK # 1, 5, 6) - (Installing) Stand Alone Sensor Interstitial Monitoring Veeder Root non discriminating in dispenser sumps

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: BMPC, Inc. 1510 Spring Bay Road, Unit E East Peoria, IL 61611	Contact Person: Brian McCormick Phone: (309) 222-5293 Contractor Registration # IL-002393 Exp. 12/12/2016
--	---

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)