



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)785-1020

<u>FOR OFFICE USE ONLY</u>
Facility # 2-034916
Permit # 00108-2015UPG
Request Rec'd 02/17/2015
Amended Date 03/02/2015
Approval Date 2/17/2015 DS
Permit Expires 8/17/2015

Amended

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Midwest Petroleum Development Company 7615 Route 14, Crystal Lake, IL 60014 Contact: Jayaprakash Reddy (815) 446-1197</p>	<p>(2) FACILITY - name and address where tanks are located: Citgo 7615 Route 14 @ Route 176 Crystal Lake, McHenry Co., IL Contact: Jayaprakash Reddy (815) 446-1197</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 3, 4, 5) - 10,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 3, 4, 5) - (Installing) Fiberglass Single Wall Piping Ameron Dualoy 3000L single wall fiberglass piping
- (d) *Product to be stored in each tank:* (TK # 3, 4) - Gasoline, (TK # 5) - Diesel Fuel
- (e) *Type of leak detection being used:*
 Tank:
 Piping:
- (f) *Corrosion Protection being used:*
 Tank:
 Piping: (TK # 3, 4, 5) - (Installing) Fiberglass Non-Corrosive
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES: The only change is the layout of the vent piping

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
B & K Equipment Company 2939 175th Street Lansing, IL 60438	Contact Person: Ed Angell Phone: (708) 474-3344 Contractor Registration # IL-1207 Exp. 02/14/2016

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist -
 Fire Department -
 Division File
 (Rev. - 9/10)