



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)785-1020

**FOR OFFICE USE ONLY**

Facility # 1-022697  
Permit # 00244-2015UPG  
Request Rec'd 03/23/2015  
Amended Date  
Approval Date 3/23/2015 DS  
Permit Expires 9/23/2015

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Commonwealth Edison/Exelon Corporation 3 Lincoln Center - Real Estate & Facilities, Oakbrook Terrace, IL 60181-4260 Contact: Robert Rogas (630) 437-2124	<b>(2) FACILITY</b> - name and address where tanks are located: Rockford Regional Reporting Center 123 Energy Ave Rockford, Winnebago Co., IL Contact: Todd Holach (630) 360-1723
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 647, 649) - 20,000 gallons, (TK # 648, 650) - 10,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 647, 648, 649, 650) - (Installing) Dispenser Sumps containment FRP, (TK # 647, 648, 649, 650) - (Installing) Submersible Sumps containment FRP, (TK # 647, 648, 649, 650) - (Installing) Flexible Double Wall OPW Flexworks CP-15 non corrosive from tanks to dispensers
- (d) *Product to be stored in each tank:* (TK # 647, 649) - Diesel Fuel, (TK # 648, 650) - Gasoline
- (e) *Type of leak detection being used:*  
*Tank:*  
*Piping:* (TK # 647, 648, 649, 650) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 in dispenser sumps, submersible sensors are existing and will be re-used
- (f) *Corrosion Protection being used:*  
*Tank:*  
*Piping:* (TK # 647, 648, 649, 650) - (Installing) Flexible Non-Corrosive
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES:**

<b><u>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</u></b> Superior Petroleum Marketers, Inc. 2336 Albright Lane, P. O.Box 4648 Wheaton, IL 60189-4648	Contact Person: Steve Tuttle Phone: (630) 588-1198 Contractor Registration # IL-2087 Exp. 02/04/2016
---	--

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist -  
Fire Department -  
Division File  
(Rev. - 9/10)