

OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)785-1020

FOR OFFICE USE ONLY

Facility # 2-018414
Permit # 00246-2015CAT
Request Rec'd 03/24/2015
Amended Date
Approval Date 3/24/2015 DS
Permit Expires 9/24/2015

Permit for INSTALLATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. A required job schedule for cathodic protection upgrade of underground storage tank(s) and piping must be submitted to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity:

Sajeel Citgo Gas & Food, Inc.

999 W. Illinois Avenue

Aurora, IL 60506

(2) FACILITY - name and address where tanks are located:

Aurora Food & Gas Service

999 W Illinois Ave

Aurora, Kane Co., IL

(3), UPGRADE, OR REPAIR OF CATHODIC PROTECTION SYSTEM:

(a) Number and size of tanks having cathodic protection installed, upgraded, or repaired: (TK # 4) - 10,000 gallons, (TK # 5) - 8,000 gallons

Contact: Mohammed Hyder (630) 768-2803

- (b) Type of tanks:
- (c) Type of piping:
- (d) Product to be stored in each tank: (TK # 4, 5) Gasoline
- (e) Type of leak detection being used:

Contact: Mohammad Latif (630) 768-2803

Tank:

Piping:

(f) Corrosion Protection being used:

Tank:

Piping: (TK # 4, 5) - (Installing) Sacrificial Anode Cathodic Protection to exposed steel in submersible sumps

(g) NACE certified designer:

Certification number:

Daniel J. Starke

- (h) Method of integrity assessment of tank(s) being used:
- (4) The owner must notify this Office when completion of cathodic protection upgrade has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for cathodic protection upgrade to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES**:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Protanic, Inc.

658 North Progress Drive, PO Box 80265

Contact Person: Dan Cope
Phone: (262) 268-1150

Saukville, WI 53080 Contractor Registration # IL-1413 Exp. 08/29/2016

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist -Fire Department -Division File

(Rev. - 9/10)