



**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL**  
**Division of Petroleum and Chemical Safety**  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)785-1020

<b>FOR OFFICE USE ONLY</b>
Facility # 6-017875
Permit # 00299-2015UPG
Request Rec'd 04/09/2015
Amended Date
Approval Date 4/9/2015 DS
Permit Expires 10/9/2015

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:          St. Mary's Good Samaritan, Inc.          400 N. Pleasant          Centralia, IL 62801          Contact: Stover Harold Jr (618) 532-6731</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:          St. Mary's Hospital          400 N. Pleasant          Centralia, Marion Co., IL          Contact: Howard Jones (618) 532-6731</p>
---	---

**(3) UPGRADE OR REPAIR OF TANKS:**


- (a) *Number and size of tanks being upgraded or repaired:* (TK # 2) - 8,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 2) - (Installing) Flexible Double Wall A.P.T. Poly Tech P150SC return line , (TK # 2) - (Installing) Tank Sump containment FRP, (TK # 2) - (Installing) 2 Transition Sumps FRP fiberglass , (TK # 2) - (Installing) Flexible Double Wall A.P.T. Poly Tech P100SC supply line **as shown in site plan**
- (d) *Product to be stored in each tank:* (TK # 2) - Diesel Fuel
- (e) *Type of leak detection being used:*  
  - Tank:* (TK # 2) - (Installing) Automatic Tank Gauging Incon TS 550
  - Piping:* (TK # 2) - (Installing) Electronic Pressurized Line Leak Detection Incon TS LLD from above ground pump cabinet to transition sump at building where piping will transition inside , (TK # 2) - (Installing) European with No Test Req Suction for piping from tank sump to above ground pump cabinet , (TK # 2) - (Installing) Piping Sump Sensors Interstitial Monitoring Incon TS 550 Sump Sensors in tank sump and in both transition sumps, one at building and one at pump cabinet
- (f) *Corrosion Protection being used:*  
  - Tank:*
  - Piping:* (TK # 2) - (Installing) Flexible Non-Corrosive
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

**(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.**

**(5) SPECIAL CONTINGENCIES:**

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>          UPC Enterprises, LC d/b/a United Petroleum Service          1458 Collins Street          St. Louis, MO 63102</p>	<p>Contact Person: Harvey Stokes          Phone: (314) 241-3767          Contractor Registration # IL-002402 Exp. 02/10/2016</p>
--	--

Sincerely,

  
\_\_\_\_\_

Daniel Starks

cc: Storage Tank Safety Specialist -  
Fire Department -  
Division File  
(Rev. - 9/10)