



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY

Facility # 2-005475
Permit # 00345-2015UPG
Request Rec'd 04/21/2015
Amended Date
Approval Date 4/21/2015 DS
Permit Expires 10/21/2015

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Chicago Executive Airport 1020 South Plant Road Wheeling, IL 60090 Contact: James Abbott (847) 537-2580	(2) FACILITY - name and address where tanks are located: Signature Flight Support 1100 S. Milwaukee Avenue Wheeling, Cook Co., IL Contact: Al Palicki (847) 537-1200
---	---

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired:* (TK # 12, 17, 18, 19) - 20,000 gallons

(b) *Type of tanks:*

(c) *Type of piping:*

(d) *Product to be stored in each tank:* (TK # 12, 18, 19) - Jet Fuel, (TK # 17) - Aviation Fuel

(e) *Type of leak detection being used:*

Tank: (TK # 12, 17, 18, 19) - (Installing) Automatic Tank Gauging OPW Site Sentinel iTouch , printer and probes, (TK # 12, 17, 18, 19) - (Installing) Hydrostatic Reservoir Sensors Interstitial Monitoring OPW Site Sentinel I-i Touch dual float

Piping: (TK # 12, 17, 18, 19) - (Installing) Piping Sump Sensors Interstitial Monitoring OPW Site Sentinel I-Touch in tanks sumps

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Metro Environmental Contractors, Inc. dba Metro Tank & Pump Company 1111 West Dundee Road Wheeling, IL 60090-3906	Contact Person: Larry Cherner Phone: (847) 465-4000 Contractor Registration # IL-102 Exp. 02/07/2016
--	--

Sincerely,

Daniel Starks