



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020
Amended

FOR OFFICE USE ONLY

Facility # 2-022817
Permit # 00097-2015UPG
Request Rec'd 02/10/2015
Amended Date 04/22/2015
Approval Date 2/10/2015 DS
Permit Expires 8/10/2015

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Ted Spyropoulos 2155 W. 80th Street Chicago, IL 60620 Contact: Michael Silbert (847) 293-4802	(2) FACILITY - name and address where tanks are located: NDS Oil, Inc. (Marathon) 5801 West Dempster Morton Grove, Cook Co., IL Contact: Hafiz Yaqoob (847) 322-6864
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 5, 6, 7) - 12,000 gallons
 - (b) *Type of tanks:*
 - (c) *Type of piping:* (TK # 5, 6, 7) - (Installing) Dispenser Sumps containment FRP under all dispensers due to shear valves being adjusted to proper heights
 - (d) *Product to be stored in each tank:* (TK # 5, 6, 7) - Gasoline
 - (e) *Type of leak detection being used:*
 - Tank:*
 - Piping:*
 - (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
 - (g) *Spill containment devices, piping, and dispenser containment devices:* (TK # 5, 6, 7) - (Installing) Manhole Pre-manufactured Emco Wheaton A1004
 - (h) *Overfill prevention devices:* (TK # 5, 6, 7) - (Installing) Overfill Drop Tube Valve Emco Wheaton A1100 Guardian
 - (i) *Manway accessible at grade:*
- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.
- (5) **SPECIAL CONTINGENCIES:** Permit amended to show dispenser sumps at all dispensers as well as adding new spill containment and overfill prevention devices

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Stephen M Kryl Phone: (708) 478-6190 Contractor Registration # IL-002275 Exp. 05/21/2016
---	--

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)