



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020
Amended

FOR OFFICE USE ONLY

Facility # 3-016233
Permit # 00288-2015UPG
Request Rec'd 04/06/2015
Amended Date 04/29/2015
Approval Date 4/6/2015 DS
Permit Expires 10/6/2015

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Evergreen F S 402 N. Hershey Road, Bloomington, IL 61702-1367 Contact: Bob Eichelberger (309) 663-2392	(2) FACILITY - name and address where tanks are located: Evergreen FS, Inc. El Paso 201 East Main Street El Paso, Woodford Co., IL Contact: Ron Armstrong (309) 645-6415
----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

(3) UPGRADE OR REPAIR OF TANKS:

- (a) **Number and size of tanks being upgraded or repaired:** (TK # 1) - 6,000 gallons
- (b) **Type of tanks:**
- (c) **Type of piping:** (TK # 1) - (Installing) Flexible Double Wall A.P.T. Poly Tech P150SC from tank to dispensing island to replace existing DW Total Containment piping which was leaking. Piping will be pulled and re-installed in existing chase piping. Sensors are existing
- (d) **Product to be stored in each tank:** (TK # 1) - Gasoline
- (e) **Type of leak detection being used:**
 - Tank:**
 - Piping:**
- (f) **Corrosion Protection being used:**
 - Tank:**
 - Piping:** (TK # 1) - (Installing) Flexible Non-Corrosive
- (g) **Spill containment devices, piping, and dispenser containment devices:**
- (h) **Overfill prevention devices:**
- (i) **Manway accessible at grade:**

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES:** Permit was amended to show tank #1 was worked on instead of tank #2

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Pemco Service Company, Inc. 1040 East Second Street Gilman, IL 60938	Contact Person: William "Butch" VonDrehle Phone: (815) 265-7364 Contractor Registration # IL-1224 Exp. 02/23/2016
-----------------------------------------------------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------------------------------------------

Sincerely,

Daniel Starks