



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY

Facility # 5-007411
Permit # 00378-2015UPG
Request Rec'd 05/04/2015
Amended Date
Approval Date 5/4/2015 DS
Permit Expires 11/4/2015

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Joseph F. Boente Sons, Inc. 543 West Main Street, Carlinville, IL 62626 Contact: David Boente (217) 854-3164	(2) FACILITY - name and address where tanks are located: 108 Shell 19022 W. Frontage Road Raymond, Montgomery Co., IL Contact: Dave Boente (217) 324-6832
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 4) - 8,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 4) - (Installing) 3 Dispenser Sumps containment FRP, (TK # 4) - (Installing) Transition Sumps FRP fiberglass, (TK # 4) - (Installing) Flexible Double Wall A.P.T. Poly Tech P150SC from new dispenser sump where piping will change from SWF to DWF and supply new dispenser island
- (d) *Product to be stored in each tank:* (TK # 4) - Diesel Fuel
- (e) *Type of leak detection being used:*
Tank:
Piping: (TK # 4) - (Installing) Piping Sump Sensors Interstitial Monitoring OPW EECO 1500 in total of 4 sumps, three new dispenser sumps and in new transition sump
- (f) *Corrosion Protection being used:*
Tank:
Piping: (TK # 4) - (Installing) Flexible Non-Corrosive
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: W J Scott Company 3861 Tozer Road Springfield, IL 62707	Contact Person: Howard Tuttle Phone: (217) 787-6081 Contractor Registration # IL-1949 Exp. 04/18/2016
--	---

Sincerely,

Daniel Starks