



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
(217)785-1020

FOR OFFICE USE ONLY

Facility # 6000762
Permit # 00400-2015UPG
Request Rec'd 05/06/2015
Amended Date
Approval Date 5/11/2015 DS
Permit Expires 11/12/2015

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) **OWNER OF TANKS** - Corporation, partnership, or other business entity:

Pilot Travel Centers, LLC
5508 Lonas Rd.
Knoxville, TN 379093221

Contact: Joey Cupp (865) 474-3026

(2) **FACILITY** - name and address where tanks are located:

Pilot Travel Center #313
699 Highway 203
East St. Louis, IL 62201

Contact: (865) 588-7488

(3) **UPGRADE OR REPAIR OF TANKS:**

(a) *Number and size of tanks being upgraded or repaired: (TK # 1, 4) - 6,000, (TK # 2, 3, 5) - 10,000*

(b) *Type of tanks: (TK # 1, 2, 3, 4, 5) Tank - Stand Alone System*

(c) *Type of piping:*

(d) *Product to be stored in each tank: (TK # 1, 2, 4) - Gasoline, (TK # 3, 5) - Diesel Fuel*

(e) *Type of leak detection being used:*

Tank: (TK # 1, 2, 3, 4, 5) Leak Detect - Tank - Interstitial Monitoring Veeder Root TLS 450

Piping:

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Mamway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES :**

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

Tank Tech, Inc.
3975 State Highway H
Sikeston, MO 63801

Contact Person: Lisa Haynes
Phone: (573) 471-1932
Contractor Registration # IL2136 Exp. 1/14/2016

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist
Division File