



Office of the Illinois State Fire Marshal
 Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 (217)785-1020

FOR OFFICE USE ONLY
 Facility # 2023052
 Permit # 00501-2015UPG
 Request Rec'd 06/01/2015
 Amended Date
 Approval Date 6/8/2015 DS
 Permit Expires 12/8/2015

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Oke Enterprises LLC 27 North Batavia Avenue Batavia, IL 60510 Contact: Stanley A. Oke (630) 879-0999</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Oke Enterprises LLC 27 North Batavia @ Houston Batavia, IL 60510 Contact: Stanley A Oke (630) 879-0999</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 5, 6, 7) - 12,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 5, 6, 7) Piping - Dispenser Sumps containment FRP*
- (d) *Product to be stored in each tank: (TK # 5) - Ultra Low Sulfur Diesel, (TK # 6, 7) - Gasoline*
- (e) *Type of leak detection being used:*
Tank:
Piping:
- (f) *Corrosion Protection being used:*
Tank:
Piping:
- (g) *Spill containment devices, piping, and dispenser containmnt devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

<p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</p>	
<p>Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108</p>	<p>Contact Person: Robert Stenstrom Phone: (815) 398-6250 Contractor Registration # IL1890 Exp. 3/7/2016</p>

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist
 Division File