



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY

Facility # 2-021373
Permit # 00509-2015REM
Request Rec'd 06/10/2015
Amended Date
Approval Date 6/10/2015 DS
Permit Expires 12/10/2015

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: GC Real Estate, LLC 100 Tri State International, Ste 140 Lincolnshire, IL 60069 Contact: Masood Mokhtarpour (630) 363-3530	(2) FACILITY - name and address where tanks are located: Forest Park Mobil 949 South Harlem Avenue Forest Park, Cook Co., IL Contact: Ali Qureshi (708) 366-9889
--	---

(3) REMOVAL OF TANKS:

- (a) *Number and size of tanks being removed:* (TK # 1, 2, 3, 4) - 10,000 gallons, (TK # 5) - 6,000 gallons
- (b) *Description/location of piping being removed:*
- (c) *Product stored in each tank:* (TK # 1, 3, 4, 5) - Gasoline, (TK # 2) - Diesel Fuel
- (d) *Reason of tanks being removed:*
- (e) *If tank(s) is leaking, indicate IEMA incident number:* 2015-0589
- (f) *Date each tank was last used:* (TK # 1, 2, 3, 4, 5) - 11/25/2014

- (4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.**

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Grand Slam Enterprises, Inc. 1770 S. Randall Road, Ste. A, Box 178 Geneva, IL 60134	Contact Person: Brian Morin Phone: (630) 377-0297 Contractor Registration # IL-002343 Exp. 11/09/2015
--	---

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)