



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020
Amended

FOR OFFICE USE ONLY

Facility # 4-045905
Permit # 00528-2015REM
Request Rec'd 06/15/2015
Amended Date 06/23/2015
Approval Date 6/15/2015 DS
Permit Expires 12/15/2015

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Illini North Development 666 E Main St Centreville, MI 49032 Contact:	(2) FACILITY - name and address where tanks are located: Vacant Lot 608 E University Ave Champaign, Champaign Co., IL Contact:
---	---

(3) REMOVAL OF TANKS:

- (a) *Number and size of tanks being removed:* (TK # 1) - 1,000 gallons, (TK # 2, 3) - 550 gallons
- (b) *Description/location of piping being removed:*
- (c) *Product stored in each tank:* (TK # 1, 2, 3) - Unknown
- (d) *Reason of tanks being removed:*
- (e) *If tank(s) is leaking, indicate IEMA incident number:*
- (f) *Date each tank was last used:* (TK # 1, 2, 3) - 12/31/1973

- (4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

- (5) **SPECIAL CONTINGENCIES:** Permit was amended to show tanks 2 & 3 added as contractor found them during removal of tank #1

(6) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u> Midwest Petroleum Service, LLC 23535 North 1530 East Road Danville, IL 61834	Contact Person: Mike Hall Phone: (217) 443-2263 Contractor Registration # IL-002306 Exp. 06/26/2016
--	---

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)