



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY

Facility # 6-011122
Permit # 00569-2015UPG
Request Rec'd 06/23/2015
Amended Date
Approval Date 6/24/2015 DS
Permit Expires 12/24/2015

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Moto, Inc. 721 W. Main St., P.O. Box 122 Belleville, IL 62222-0122 Contact: Rob Whittington (618) 233-6754 Ext. 106	(2) FACILITY - name and address where tanks are located: Highland Moto Mart 700 West Broadway Highland, Madison Co., IL Contact: Mary Frohn (618) 654-4343
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 4) - 10,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 4) - (Installing) Partial Fiberglass Single Wall Piping at Western most dispenser sumps to connect current Diesel piping to existing UL line under dispensers
- (d) *Product to be stored in each tank:* (TK # 4) - Diesel Fuel
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:* (TK # 4) - (Installing) Fiberglass Non-Corrosive
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES:** Per scope of work, contractor will be connecting current diesel line to the existing Super UL line (which will be capped at the tank) at the Western most dispenser sumps. Tank #4 will be cleaned and converted to RUL in order to supply to all 3 existing dispensers. Tanks 1-3 and their associated piping will be abandoned under a separate permit due to failing an internal lining inspection.

<u>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</u> UPC Enterprises, LC d/b/a United Petroleum Service 1458 Collins Street St. Louis, MO 63102	Contact Person: Terry Smith Phone: (314) 241-3767 Contractor Registration # IL-002402 Exp. 02/10/2016
--	---

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)