



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020
Amended

FOR OFFICE USE ONLY

Facility # 2-014721
Permit # 00362-2015UPG
Request Rec'd 04/27/2015
Amended Date 06/25/2015
Approval Date 4/27/2015 DS
Permit Expires 10/27/2015

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: AZ SPE, LLC 12345 S. Keeler Ave. Alsip, IL 60803 Contact: Dave Sweis	(2) FACILITY - name and address where tanks are located: Elmwood Park Phillips 66 7750 West Grand Avenue Elmwood Park, Cook Co., IL Contact: Azzem Syed (708) 456-9705
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 1, 2) - 10,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 1, 2) - (Installing) Partial Steel Single Wall Piping to accomodate new dispenser sump and also to allow the installation of sumps under existing dispensers to allow the adjustment of the sheer valve heights to bring into compliance, (TK # 1, 2) - (Installing) Dispenser Sumps containment FRP
- (d) *Product to be stored in each tank:* (TK # 1, 2) - Gasoline
- (e) *Type of leak detection being used:*
 - Tank:
 - Piping:
- (f) *Corrosion Protection being used:*
 - Tank:
 - Piping:
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES:** Permit request recieved 6/24 to add an additional Diesel dispenser sump which requires extending existing sw steel piping less than 20' to accomodate new dispenser

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Metro Environmental Contractors, Inc. dba Metro Tank & Pump Company 1111 West Dundee Road Wheeling, IL 60090-3906	Contact Person: Larry Cherner Phone: (847) 465-4000 Contractor Registration # IL-102 Exp. 02/07/2016
--	--

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)