



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)785-1020  
**Amended**

**FOR OFFICE USE ONLY**

Facility # 6-013718  
Permit # 00545-2015UPG  
Request Rec'd 06/17/2015  
Amended Date 07/08/2015  
Approval Date 6/17/2015 DS  
Permit Expires 12/17/2015

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Western Oil, Inc. 3473 Rider Trail South Earth City, MO 63045 Contact: George Eble (314) 738-9900	<b>(2) FACILITY</b> - name and address where tanks are located: Petro Mart #75 980 East Ferguson Avenue Wood River, Madison Co., IL Contact: Mary Ann Wilhite (618) 254-5020
---	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 9, 10) - 12,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 9, 10) - (Installing) Steel Single Wall Riser Piping
- (d) *Product to be stored in each tank:* (TK # 9, 10) - Gasoline
- (e) *Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) *Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:* (TK # 9, 10) - (Installing) Manhole Pre-manufactured OPW 1-2100
- (h) *Overfill prevention devices:* (TK # 9, 10) - (Installing) Overfill Drop Tube Valve OPW 61T straight drop tube
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES:** Permit was amended to add drop tubes

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b> Neumayer Equipment Company, Inc. 5060 Arsenal Street Saint Louis, MO 63139	Contact Person: Alex Griffith Phone: (314) 772-4501 Contractor Registration # IL-1502 Exp. 03/26/2016
---	---

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist -  
Fire Department -  
Division File  
(Rev. - 9/10)