



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY

Facility # 6-023727
Permit # 00671-2015UPG
Request Rec'd 07/16/2015
Amended Date
Approval Date 7/16/2015 SB
Permit Expires 1/18/2016

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Shingara Singh 220 N. Shamrock East Alton, IL 62024 Contact:	(2) FACILITY - name and address where tanks are located: Main Street Market 220 N. Shamrock East Alton, Madison Co., IL Contact: Bhadresh Doshi (618) 917-6912
--	---

(3) UPGRADE OR REPAIR OF TANKS:


- (a) *Number and size of tanks being upgraded or repaired:* (TK # 1, 2, 3) - 8,200 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 1, 2, 3) - (Installing) Flex Connector Steel, (TK # 1, 2, 3) - (Installing) Flexible Double Wall A.P.T. Poly Tech P150SC from existing tanks to existing dispensers, (TK # 1, 2, 3) - (Installing) Dispenser Sumps containment FRP, (TK # 1, 2, 3) - (Installing) Shear Valves, (TK # 1, 2, 3) - (Installing) Submersible Sumps containment FRP
- (d) *Product to be stored in each tank:* (TK # 1, 2) - Gasoline, (TK # 3) - Diesel Fuel
- (e) *Type of leak detection being used:*
Tank:
Piping: (TK # 1, 2, 3) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 in all submersible and all dispenser sumps
- (f) *Corrosion Protection being used:*
Tank:
Piping:
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES:** This permit replaces permit #00017-2015UPG. The permit expired before completion of the job.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Fuel Up Technologies, LLC 2060 Craigshire Drive St. Louis, MO 63146	Contact Person: Dave Hanson Phone: 314-865-0751 Contractor Registration # IL-002405 Exp. 08/08/2016
--	---

Sincerely,



Daniel Starks