



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)785-1020

<u>FOR OFFICE USE ONLY</u>
Facility # 2-027814
Permit # 00416-2015UPG
Request Rec'd 05/12/2015
Amended Date 08/06/2015
Approval Date 5/12/2015 DS
Permit Expires 11/12/2015

Amended

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Vidhya 3rd, Inc. 17845 Ridge Road Minooka, IL 60447 Contact: Dixit Patel (630) 479-1529</p>	<p>(2) FACILITY - name and address where tanks are located: Minooka Citgo, Inc. 17845 Ridge Road Minooka, Grundy Co., IL Contact: Dixit Patel (630) 479-1529</p>
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 1) - 12,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 1) - (Installing) Dispenser Sumps containment FRP, (TK # 1) - (Installing) Submersible Sumps containment FRP, (TK # 1) - (Installing) Fiberglass Double Wall Ameron Dualoy 3000/LCX from existing tank to new dispenser islands
- (d) *Product to be stored in each tank:* (TK # 1) - Gasoline
- (e) *Type of leak detection being used:*
Tank:
Piping: (TK # 1) - (Installing) Mechanical Pressurized Line Leak Detection FE Petro STP-MLD-D , (TK # 1) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 in all dispenser and submersible sumps
- (f) *Corrosion Protection being used:*
Tank:
Piping: (TK # 1) - (Installing) Fiberglass Non-Corrosive
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES: Permit was amended to show the location of the vent lines changing from the building to the canopy column

<p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</p>	
<p>BMPC, Inc. 1510 Spring Bay Road, Unit E East Peoria, IL 61611</p>	<p>Contact Person: Brian McCormick Phone: (309) 222-5293 Contractor Registration # IL-002393 Exp. 12/12/2016</p>

Sincerely,

Daniel Starks