



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 3032913
Permit # 00746-2015UPG
Request Rec'd 08/03/2015
Amended Date 08/10/2015
Approval Date 8/4/2015 DS
Permit Expires 8/18/2015

**Permit for Emergency Repair Request on 8/3/2015
Amended**

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: 7-Eleven, Inc. 1722 Routh St., Suite 1000, Gas Compliance PO Box 711 Dallas, TX 75201 Contact: Scott Thomas Johnson (847) 608-1136	(2) FACILITY - name and address where tanks are located: 7-Eleven Store #34469 3105 175th Avenue Sherrard, IL 61281 Contact: Scott Lang (309) 593-2981
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 1) - 10,000, (TK # 2) - 8,000*
 - (b) Type of tanks:*
 - (c) Type of piping: (TK # 1) Piping - Fiberglass Single Wall Piping Ameron , (TK # 1, 2) Piping - Steel Single Wall Piping*
 - (d) Product to be stored in each tank: (TK # 1, 2) - Gasoline*
 - (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
 - (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
 - (g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 1, 2) Spill Contain Device - Manhole Pre-manufactured OPW Edge 1C-3112D spill containment manhole*
 - (h) Overfill prevention devices: (TK # 1, 2) Overfill Prev Device - Overfill Drop Tube Valve OPW 7ISO-410C overfill drop tube*
 - (i) Manway accessible at grade:*
- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.
- (5) SPECIAL CONTINGENCIES** : tank testing completed on 8/6, we have found a vacuum leak on the single wall vent risers protruding up canopy columns, would like to amend permit to run new 2 " galvanized vent stack externally on the canopy column, Depending on condition of vent extractor valve and if we will be able to seal the tank isolation plug for testing purposes the extractor valves may need to be replaced as well.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:


Seneca Companies, Inc.

Contact Person: Keri Hankins

4140 East 14th Street PO Box 3360
Des Moines, IA 50313

Phone: (816) 761-1270
Contractor Registration # IL598 Exp. 2/23/2016

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File