



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

<b>FOR OFFICE USE ONLY</b>
Facility # 7007501
Permit # 00768-2015UPG
Request Rec'd 08/07/2015
Amended Date
Approval Date 8/10/2015 DS
Permit Expires 2/10/2016

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Martin &amp; Bayley, Inc. 1311 A West Main Street PO Box 385 Carmi, IL 62821</p> <p>Contact: Troy Dietz (618) 382-2334</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Hucks #51 I-57 &amp; Highway 15 Mount Vernon, IL 62867</p> <p>Contact: Mark Bayley (618) 382-2334</p>
--	---


- (3) UPGRADE OR REPAIR OF TANKS:**
- (a) Number and size of tanks being upgraded or repaired: (TK # 4, 5, 6) - 20,000*
  - (b) Type of tanks:*
  - (c) Type of piping: (TK # 4, 5, 6) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX from existing tanks to new transition sump , (TK # 4, 5, 6) Piping - Transition Sumps FRP fiberglass, (TK # 5) Piping - Valves Ball Valve*
  - (d) Product to be stored in each tank: (TK # 4, 5, 6) - Diesel Fuel*
  - (e) Type of leak detection being used:*  
*Tank:*  
*Piping: (TK # 4, 5, 6) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 in submersible sumps and in new transition sump*
  - (f) Corrosion Protection being used:*  
*Tank:*  
*Piping:*
  - (g) Spill containment devices, piping, and dispenser containmnt devices:*
  - (h) Overfill prevention devices:*
  - (i) Manway accessible at grade:*
- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.
- (5) SPECIAL CONTINGENCIES :** Will be removing existing existing loading equipment from tank #5 and install new piping from tank to newly installed transition sump in new install shed building. Will rework existing diesel trunk line from other two tanks, #4 and #6, to enter the transition sump and have this piping run through blending equipment. Will install new piping from blending equipment through transition sump to tie into existing piping running to dispensers. Will be install sump sensor for transition sump and install check valve and ball valves on the new B-99 pipe lines.

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>
---

Neumayer Equipment Company, Inc.  
5060 Arsenal Street  
Saint Louis, MO 63139

Contact Person: Kerri McKay  
Phone: (314) 932-3783  
Contractor Registration # IL1502 Exp. 3/26/2016

Sincerely,

  
\_\_\_\_\_

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File