



**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL**  
**Division of Petroleum and Chemical Safety**  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)785-1020

<b>FOR OFFICE USE ONLY</b>
Facility # 5-002653
Permit # 00789-2015CAT
Request Rec'd 08/11/2015
Amended Date
Approval Date 8/11/2015 DS
Permit Expires 2/11/2016

**Permit for INSTALLATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. A required job schedule for cathodic protection upgrade of underground storage tank(s) and piping must be submitted to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:          Sona Corporation I          P.O. Box 736          Kincaid, IL 62540          Contact: Mike Amin (217) 303-4584</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:          Kincaid Phillips 66          400 Springfield Rd.          Kincaid, Christian Co., IL          Contact: Mike Amin (217) 237-2421</p>
--	---

**(3) , UPGRADE, OR REPAIR OF CATHODIC PROTECTION SYSTEM:**

- (a) **Number and size of tanks having cathodic protection installed, upgraded, or repaired:** (TK # 6) - 10,000 gallons, (TK # 7, 8) - 6,000 gallons
- (b) **Type of tanks:**
- (c) **Type of piping:**
- (d) **Product to be stored in each tank:** (TK # 6, 7) - Gasoline, (TK # 8) - Diesel Fuel
- (e) **Type of leak detection being used:**  
 Tank:  
 Piping:
- (f) **Corrosion Protection being used:**  
 Tank:  
 Piping: (TK # 6, 7, 8) - (Installing) Sacrificial Anode Flex Connector spike anode in all submersible and dispenser sumps per N.O.V.
- (g) **NACE certified designer:** Certification number:
- (h) **Method of integrity assessment of tank(s) being used:**

**(4) The owner must notify this Office when completion of cathodic protection upgrade has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for cathodic protection upgrade to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.**

**(5) SPECIAL CONTINGENCIES:**

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b></p>	
<p>W J Scott Company          3861 Tozer Road          Springfield, IL 62707</p>	<p>Contact Person: George Eames          Phone: (217) 787-6081          Contractor Registration # IL-1949 Exp. 04/18/2016</p>

Sincerely,

Daniel Starks