



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 2009070  
Permit # 00822-2015UPG  
Request Rec'd 07/20/2015  
Amended Date  
Approval Date 8/17/2015 DS  
Permit Expires 2/17/2016

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

|                                                                                                                                                                                                                      |                                                                                                                                                                                                 |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <p>(1) <b><u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Buchanan Energy N, LLC<br/>4973 Dodge Street<br/>Omaha, NE 68132</p> <p>Contact: Nichole Mallett (402) 558-9860</p> | <p>(2) <b><u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Bucky's Express #422<br/>9401 West Higgins Road<br/>Rosemont, IL 60066</p> <p>Contact: Andy (815) 423-7659</p> |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired: (TK # 6) - 10,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 6) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX from existing tank to existing dispenser, both have existing sumps, (TK # 6) Piping - Shear Valves, (TK # 6) Piping - Valves Ball Valve, (TK # 6) Piping - Flex Connector Steel*
- (d) *Product to be stored in each tank: (TK # 6) - Gasoline*
- (e) *Type of leak detection being used:*
  - Tank:*
  - Piping: (TK # 6) Leak Detect - Piping - Electronic Pressurized Line Leak Detection Veeder Root TLS 350 PLLD leak sensors, sump sensors are existing*
- (f) *Corrosion Protection being used:*
  - Tank:*
  - Piping: (TK # 6) Corrosion Prot - Piping - Fiberglass Non-Corrosive*
- (g) *Spill containment devices, piping, and dispenser containmnt devices: (TK # 6) Spill Contain Device - Manhole Pre-manufactured OPW 1C-2115 DEVR spill containment manhole*
- (h) *Overfill prevention devices: (TK # 6) Overfill Prev Device - Ball Float Vent Valve OPW 53VML*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Stenstrom Petroleum Services Group  
2422 Center Street  
Rockford, IL 61108

Contact Person: Robert Stenstrom  
Phone: (815) 398-6250  
Contractor Registration # IL1890 Exp. 3/7/2016

Sincerely,

*Daniel G. Starks*

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File