



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY

Facility # 1-039830
Permit # 00832-2015UPG
Request Rec'd 08/18/2015
Amended Date
Approval Date 8/19/2015 DS
Permit Expires 2/19/2016

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Kelley Williamson Company 1132 Harrison Avenue Rockford, IL 61104 Contact: Bob Sanders (815) 397-9410	(2) FACILITY - name and address where tanks are located: Wheeler Road Mobil 5955 Wheeler Road Cherry Valley, Winnebago Co., IL Contact: Bob Sanders (815) 397-9410
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 3) - 8,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 3) - (Installing) Flexible Double Wall A.P.T. Poly Tech P200SC from primary diesel dispenser to the center master diesel dispenser as shown in site plan, (TK # 3) - (Installing) Shear Valves under all new dispensers, (TK # 3) - (Installing) Dispenser Sumps containment FRP, (TK # 3) - (Installing) Flexible Double Wall A.P.T. Poly Tech P150SC from the primary diesel dispenser to the satellite dispenser as shown in site plan
- (d) *Product to be stored in each tank:* (TK # 3) - Diesel Fuel
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES:** Contractor is replacing existing Diesel dispensers. Existing sump sensors will be re-used

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Oil Equipment Company, Inc. 4701 Lien Road Madison, WI 53704	Contact Person: Dave Schmill Phone: (608) 249-2881 Contractor Registration # IL-1318 Exp. 10/29/2016
---	--

Sincerely,

Daniel Starks