



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

<b>FOR OFFICE USE ONLY</b>
Facility # 2027697
Permit # 00868-2015UPG
Request Rec'd 08/24/2015
Amended Date
Approval Date 8/25/2015 DS
Permit Expires 2/25/2016

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Golden Topaz 7005 Emerson Street Morton Grove, IL 60053</p> <p>Contact: Jalaluddin Warsani (312) 388-2531</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Touhy Shell 4000 West Touhy Lincolnwood, IL 60712</p> <p>Contact: William Franklin (847) 675-6070</p>
---	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 5) - 12,000, (TK # 6) - 8,000, (TK # 7) - 6,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 5, 6, 7) Piping - Submersible Sumps containment FRP*
- (d) Product to be stored in each tank: (TK # 5, 6) - Gasoline, (TK # 7) - Diesel Fuel*
- (e) Type of leak detection being used:*
  - Tank: (TK # 5, 6, 7) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD*
  - Piping: (TK # 5, 6, 7) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection Red Jacket FX1, (TK # 5, 6, 7) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 discriminating containment sump in new submersible sumps*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 5, 6, 7) Spill Contain Device - Manhole Pre-manufactured OPW 1-2100C DEVR spill containment manhole*
- (h) Overfill prevention devices: (TK # 5, 6, 7) Overfill Prev Device - Overfill Drop Tube Valve OPW 71SO-400C*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.


**(5) SPECIAL CONTINGENCIES : Installing new FRP tank sumps to contain submersible pumps. Revising existing SWFRP piping only as needed to install new tank sumps. Installing new Spill manholes, Overfill valves, and Tank Monitor System & Mech Leak detectors.**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>
---

Performance Tank, Inc.  
730 Creel Drive  
Wood Dale, IL 60191

Contact Person: Tim Berg  
Phone: (630) 860-9500  
Contractor Registration # IL881 Exp. 10/27/2016

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in black ink and is positioned above a thin horizontal line.

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File