



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

| |
|----------------------------|
| FOR OFFICE USE ONLY |
| Facility # 4009542 |
| Permit # 00915-2015UPG |
| Request Rec'd 09/02/2015 |
| Amended Date |
| Approval Date 9/2/2015 DS |
| Permit Expires 3/2/2016 |

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

| | |
|---|---|
| <p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>HPT TA Properties, LLC 24601 Center Ridge Road Westlake, OH 44145</p> <p>Contact: Kenny Kucker (440) 808-7368</p> | <p>(2) FACILITY - name and address where tanks are located:</p> <p>Effingham Travel Center 1702 West Evergreen I-57, I-70 & 32/33, Exit 170 Effingham, IL 62401</p> <p>Contact: Chad Hildebrand (217) 347-7183</p> |
|---|---|

(3) UPGRADE OR REPAIR OF TANKS:

(a) Number and size of tanks being upgraded or repaired: (TK # 1, 2) - 12,000

(b) Type of tanks:

(c) Type of piping: (TK # 1, 2) Piping - Sumps Entry Boots

(d) Product to be stored in each tank: (TK # 1, 2) - Gasoline

(e) Type of leak detection being used:

Tank:

Piping:

(f) Corrosion Protection being used:

Tank:

Piping:

(g) Spill containment devices, piping, and dispenser containment devices:

(h) Overfill prevention devices:


(i) Manway accessible at grade:

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES : Contractor replacing entry boots on all 6 gasoline dispenser sumps and also breaking concrete at transition sump between diesel dispensers 1 & 2 to check for leaking boots/product piping

| | |
|---|--|
| (6) PERSON, FIRM OR COMPANY PERFORMING WORK: | |
| <p>Petro Maintenance 8766 E 1200th Ave. PO Box 194 Robinson, IL 62454</p> | <p>Contact Person: John B McKeighan Phone: (618) 544-7448 Contractor Registration # IL725 Exp. 3/15/2016</p> |

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File