



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 4038592  
Permit # 00956-2015UPG  
Request Rec'd 09/10/2015  
Amended Date  
Approval Date 9/10/2015 DS  
Permit Expires 3/10/2016

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Lanman Oil Company P.O. Box 108 Charleston, IL 61920 Contact: Mike Lanman (217) 348-8020</p>	<p>(2) <b>FACILITY</b> - name and address where tanks are located:</p> <p>Lambo's Amoco III 100 Miller Road Mattoon, IL 61938 Contact: Ron Bateman (217) 235-1227</p>
--	---

(3) **UPGRADE OR REPAIR OF TANKS:**

(a) *Number and size of tanks being upgraded or repaired: (TK # 1, 5) - 15,000, (TK # 2) - 8,200*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 1, 2) Piping - Flexible Double Wall OPW Flexworks CP-15 non corrosive from all existing tanks to existing gasoling islands through existing chase piping, (TK # 1, 2, 5) Piping - Shear Valves, (TK # 1, 2, 5) Piping - Valves Ball Valve, (TK # 1, 2) Piping - Submersible Sumps containment FRP, (TK # 1, 2, 5) Piping - Sumps Entry Boots, (TK # 5) Piping - Flexible Double Wall A.P.T. Poly Tech P175SC from existing tanks to new dispenser islands, (TK # 5) Piping - Dispenser Sumps containment FRP*

(d) *Product to be stored in each tank: (TK # 1, 2) - Gasoline, (TK # 5) - Diesel Fuel*

(e) *Type of leak detection being used:*

*Tank:*

*Piping: (TK # 1, 2, 5) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 interstitial piping float sensor in all dispenser and submersible sumps*

(f) *Corrosion Protection being used:*

*Tank:*

*Piping:*

(g) *Spill containment devices, piping, and dispenser containmnt devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES :**

Tanks 1&2 installing new FRP tank sumps, Veeder Root float sump sensors in all 12 sumps, new OPW 1.5" flex works DW piping installed through the existing 4" ducted chase. Dispensers, islands & canopy remain.

Tank # 5 installing (3) new Gilbarco 700S Diesel dispensers with DEF, (3) 4' x 8' SS islands with APT poly dispenser sumps, veeder


float sump sensors, APT XP-175-SC DWflex piping from the existing diesel tank sump to the three new islands & a 24' x 48' six column canopy

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Seneca Companies, Inc.  
4140 East 14th Street PO Box 3360  
Des Moines, IA 50313

Contact Person: Keri Hankins  
Phone: (816) 761-1270  
Contractor Registration # IL598 Exp. 2/23/2016

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in black ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File