



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020
Extended

FOR OFFICE USE ONLY
Facility # 2-001089
Permit # 00205-2015INS
Request Rec'd 03/16/2015
Amended Date
Approval Date 3/16/2015 DS
Permit Expires 3/16/2016

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Love's Travel Stops & Country Stores, Inc. P.O. Box 262100, 10601 N Pennsylvania Avenue Oklahoma City, OK 73120 Contact: Chris Weldon (405) 302-6673	(2) FACILITY - name and address where tanks are located: Love's Travel Stop #606 1533 E 162Nd St South Holland, Cook Co., IL Contact: Gibson James (312) 339-7400
--	--

(3) INSTALLATION OF TANKS:


- (a) **Number and size of tanks being installed:** (TK # 6) - 8,000 gallons, (TK # 7, 13) - 12,000 gallons, (TK # 8, 9, 10, 11, 12) - 20,000 gallons
- (b) **Type of tanks:** (TK # 6, 7, 8, 9, 10, 11, 12, 13) - (Installing) Fiberglass Double Wall Containment Solutions
- (c) **Type of piping:** (TK # 6, 7, 8, 9, 10, 11, 12, 13) - (Installing) Submersible Sumps containment FRP, (TK # 6, 7, 8, 9, 10, 11, 12, 13) - (Installing) Dispenser Sumps containment FRP, (TK # 6, 7, 8, 9, 10, 11, 12, 13) - (Installing) Fiberglass Double Wall Ameron Dualoy 3000/LCX
- (d) **Product to be stored in each tank:** (TK # 6, 7, 8) - Gasoline, (TK # 9) - B-99, (TK # 10, 11, 12) - Diesel Fuel, (TK # 13) - Diesel Exhaust Fluid (Non-Regulated)
- (e) **Type of leak detection being used:**
Tank: (TK # 6, 7, 8, 9, 10, 11, 12, 13) - (Installing) Interstitial Monitoring Veeder Root TLS 350 , (TK # 6, 7, 8, 9, 10, 11, 12, 13) - (Installing) Automatic Tank Gauging Veeder Root TLS 350
Piping: (TK # 6, 7, 8, 9, 10, 11, 12, 13) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 , (TK # 6, 7, 8, 9, 10, 11, 12, 13) - (Installing) Electronic Pressurized Line Leak Detection Veeder Root TLS 350
- (f) **Corrosion Protection being used:**
Tank: (TK # 6, 7, 8, 9, 10, 11, 12, 13) - (Installing) Fiberglass Non-Corrosive
Piping: (TK # 6, 7, 8, 9, 10, 11, 12, 13) - (Installing) Fiberglass Non-Corrosive
- (g) **Spill containment devices, piping and dispenser containment devices:** (TK # 6, 7, 8, 9, 10, 11, 12, 13) - (Installing) Manhole Pre-manufactured EBW 400 CS , (TK # 6, 7, 8, 9, 10, 11, 12, 13) - (Installing) Field Constructed
- (h) **Overfill prevention devices:** (TK # 6, 7, 8, 9, 10, 11, 12, 13) - (Installing) Overfill Alarm Veeder Root TLS 350
- (4) **The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.**
- (5) **GENERAL REQUIREMENTS:** There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.
- (6) **SPECIAL CONTINGENCIES:** Refer to section 175.405 (spill containment and overfill prevention), section 175.410 (containment sumps), and section 175.445 (fill pipes/remote fills) for further guidance on the fill ports/fill trough for the Diesel tanks. The tops of the tanks being siphoned together and the Diesel tanks must be within 6" elevation of each other. Before the future siphon bar can be put into use, a written request must be recieved by this office from the owner/contractor, with subsequent approval.

(7) PERSON, FIRM OR COMPANY PERFORMING WORK:

Illinois Oil Marketing Equipment, Inc.

Contact Person: Chris Epkins
Phone: (309) 347-1819

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)