



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

| |
|----------------------------|
| FOR OFFICE USE ONLY |
| Facility # 7023851 |
| Permit # 00970-2015UPG |
| Request Rec'd 09/14/2015 |
| Amended Date |
| Approval Date 9/14/2015 DS |
| Permit Expires 3/15/2016 |

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

| | |
|---|---|
| <p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Martin & Bayley, Inc. 1311 A West Main Street PO Box 385 Carmi, IL 62821</p> <p>Contact: Mark Bayley (618) 382-2334</p> | <p>(2) FACILITY - name and address where tanks are located:</p> <p>Hucks #241 101 W. Main St. Fairfield, IL 62837</p> <p>Contact: Joe Smith (618) 382-2334</p> |
|---|---|

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 2) - 6,000, (TK # 3, 4) - 10,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 2, 3, 4) Piping - Shear Valves, (TK # 2, 3, 4) Piping - Dispenser Sumps containment FRP*
- (d) Product to be stored in each tank: (TK # 2, 3, 4) - Gasoline*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES : Removing islands and installing new dispenser sumps and anchoring shear valves at proper heights

| | |
|--|---|
| (6) PERSON, FIRM OR COMPANY PERFORMING WORK: | |
| <p>Hinderliter Construction & Maint., Inc. 3601 North St. Joseph Avenue Evansville, IN 47720</p> | <p>Contact Person: Mark Hinderliter Phone: (812) 425-4137 Contractor Registration # IL646 Exp. 4/2/2016</p> |

Sincerely,

Daniel G. Starks

Daniel Starks

cc: Storage Tank Safety Specialist
Division File