



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 2009879  
Permit # 00971-2015UPG  
Request Rec'd 09/03/2015  
Amended Date  
Approval Date 9/14/2015 DS  
Permit Expires 3/15/2016

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <b><u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Krish Ria Convenience, Inc. 1660 W. Main Street St. Charles, IL 60174</p> <p>Contact: Pregnesh Shaw (630) 926-5937</p>	<p>(2) <b><u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Krish Ria Convenience, Inc. 1600 W. Main Street St. Charles, IL 60174</p> <p>Contact: Pragnesh Shah (630) 926-5937</p>
---	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired: (TK # 3, 4) - 12,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 3, 4) Piping - Partial Fiberglass Single Wall Piping Ameron Dualoy 3000L single wall fiberglass piping to accomodate new dispenser sumps, (TK # 3, 4) Piping - Shear Valves, (TK # 3, 4) Piping - Dispenser Sumps containment FRP, (TK # 3, 4) Piping - Sumps Entry Boots, (TK # 3, 4) Piping - Flex Connector Steel*
- (d) *Product to be stored in each tank: (TK # 3, 4) - Gasoline*
- (e) *Type of leak detection being used:*
  - Tank:*
  - Piping: (TK # 3, 4) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 Plus in new dispenser sumps*
- (f) *Corrosion Protection being used:*
  - Tank:*
  - Piping: (TK # 3, 4) Corrosion Prot - Piping - Fiberglass Non-Corrosive*
- (g) *Spill containment devices, piping, and dispenser containmnt devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.


- (5) **SPECIAL CONTINGENCIES** : Installing sensors under 4 dispensers only. Installing new dispenser containment. Will cut piping back to accommodate the dispenser containment & will replace the 2-3' of pipe removed at each island only.

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Crowne Industries, Ltd.  
651 S. Sutton Road #214

Contact Person: Robert Sumoski  
Phone: (630) 497-9009

Sincerely,

A handwritten signature in cursive script, reading "Daniel G. Starks", is written over a horizontal line.

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File